

OSNABRUCK CENTRE WELL SUPPLY SUMMARY REPORT

Municipality: Township of South Stormont

Year: 2007

Description: Ground Water Source, Chlorination

Month	Treated Flow		Treated Water Physical/Chemical Parameters					
	Total Flow m ³	Avg. Day m ³ /day	Free Chlorine Residual			Raw Water	Safe	Unsafe
			Avg. mg/L	Min. mg/L	Max. mg/L		Distribution	Distribution
January	93.0	6.0	1.14	0.12	3.42	1	5	
February	84.0	6.0	1.35	0.38	2.72	1	4	
March	91.0	6.0	1.20	0.37	3.18	1	4	
April	92.0	5.0	1.23	0.09	2.49	1	4	
May	98.0	4.0	1.18	0.41	3.56	1	5	
June	93.0	6.0	1.00	0.26	3.91	1	4	
July	101.0	6.0	0.97	0.38	1.84	1	5	
August	109.0	5.0	0.81	0.35	1.57	1	4	
September	70.0	5.0	0.75	0.46	0.99	1	4	
October	94.0	6.0	0.88	0.45	1.21	1	5	
November	86.0	5.0	0.86	0.42	1.81	1	4	
December	98.0	8.0	1.00	0.61	1.34	1	4	
Total	1109					12	52	
Average		5.7	1.03					
Minimum				0.09				
Maximum					3.91			
ODWS						12	26	

